



P. O. BOX 6097
HOUMA, LOUISIANA 70361
(985) 868-5050



P. O. BOX 2768
HOUMA, LOUISIANA 70361
(985) 868-3000

TERREBONNE PARISH
CONSOLIDATED GOVERNMENT

October 15, 2009
2nd Review
Agenda Item F2

TO: **Pat Gordon**

FROM: **Gregory E. Bush, LTC, USA, Retired**
Director of Public Works

SUBJECT: **Burnette Place Subdivision;**
Review of Engineering Approval

The Engineering Division of the Terrebonne Parish Department of Public Works has reviewed the plans, specifications and calculations for the above referenced subdivision. The revised plans, specifications and calculations fail to comply with Parish Ordinances and Subdivision Regulations in the following areas:

1. 24.7.6.2.6 Does not conform to SDDM:
 - a. V.A.2. Not enough information was provided to determine if this development blocks drainage of the neighboring properties.
 - b. V.A.7. Show more detail for tie-in to existing catch basins.
2. 22-353(d) Copy of the Notice of Intent (NOI) must be submitted.

This review does not imply that this subdivision submitted complies with all other requirements of the Parish Codes. Please feel free to contact me if you have any questions or comments.

cc: Tom Bourg
Clay Breaud
Philip Liner
Planning Commission
Engineering Division
Reading File
Council Reading File