


**T e r r e b o n n e P a r i s h C o n s o l i d a t e d  
G o v e r n m e n t**

**B U Q U E T B R I D G E O V E R G R A N D C A I L L O U  
H U R R I C A N E I D A R E P A I R S**

**A d d e n d u m # 3**



**Subject: TPCG Hurricane Ida Recovery  
Purpose: Addendum 3  
Today's Date: 11/8/24**




<p><b>Addendum #3</b></p>	<p>This Addendum forms part of the Bid Documents and modifies and clarifies the original Bidding/Proposal Documents for the project as noted below. Acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject the Bidder to disqualification. Bidder is responsible to disseminate this Addendum to all subcontractors concerned.</p>
<p><b>Specification &amp; Contract Document Revisions</b></p>	<p>General:</p> <ol style="list-style-type: none"> <li>1. <b>A non-mandatory Pre-bid Conference was held on Thursday, November 7, 2024 at 10:00am. Conference agenda and a copy of the sign-in sheet are included as part of this Addendum for reference.</b></li> <li>2. <b>Bid Date and Time is postponed. Bids are due on or prior to 2:00 p.m. on Tuesday, December 10, 2024.</b></li> <li>3. Please see below clarifications, questions and answers</li> </ol>
<p><b>Clarifications</b></p>	<p>There was mention in the Pre-Bid Conference regarding "Buy America" requirements for this project. Please see below excerpt outlined in the Front Ends Specifications; Attachment B – Sample Contract; Section 14.30.</p> <p><i>14.30. Domestic Preferences for Procurements – As appropriate, and to the extent consistent with law, the contractor should, to the greatest extent practicable, provide a preference for the purchase, acquisition, or use of goods, products, or materials produced in the United States. This includes, but is not limited to iron, aluminum, steel, cement, and other manufactured products.</i></p> <p><i>For purposes of this clause:</i></p> <p><i>Produced in the United States means, for iron and steel products, that all manufacturing processes, from the initial melting stage through the application of coatings, occurred in the United States.</i></p> <p><i>Manufactured products mean items and construction materials composed in whole or in part of non-ferrous metals such as aluminum; plastics and polymer-based products such as polyvinyl chloride pipe; aggregates such as concrete; glass, including optical fiber; and lumber."</i></p>

**T e r r e b o n n e P a r i s h C o n s o l i d a t e d  
G o v e r n m e n t**

**B U Q U E T B R I D G E O V E R G R A N D C A I L L O U  
H U R R I C A N E I D A R E P A I R S**

**A d d e n d u m # 3**

<b>Questions</b>	<p>Question: Does the bridge operate sufficiently to lower the lift span and raise the counterweight? The design includes provisions to temporarily support the counterweight in the 'counterweight up' position. Can the contractor rely on the normal operation of the bridge to raise the counterweight to the 'up' position and use the temporary support system as specified in the plan set, without the need for additional lifting methods to achieve the temporary support elevation limits?</p> <p><i>Answer: You should only need to lower the span once to remove the counterweights so you can use the bridge controls and engage the starters as needed.</i></p> <p>Question: Do the FEMA provisions apply to all items or only to the quantities as noted by (FEMA PARTICIPATING)? Some base bid items include (FEMA PARTICIPATING) in the description and other do not. Are all base bid items FEMA Participating?</p> <p><i>Answer: YES, all Base Bid Items are FEMA Participating.</i></p>
	<p>End of Addendum #3</p>



**Date:** November 7, 2024 @ 10 AM

**Project:** Terrebonne Parish Consolidated Government  
Buquet Bridge Over Grand Caillou Hurricane Ida Repairs

## PRE-BID CONFERENCE AGENDA

### 1. Introductions – Please make sure to sign-in

- a. Owner – Terrebonne Parish Consolidated Government (TPCG)
- b. Engineer – Huval and Associates
- c. Program Manager – Royal Engineers and Consultants

### 2. Scope of Work

- Repairs and upgrades to current codes to Hurricane Ida Damaged Buquet Bridge.

### 3. Delivery of Bids:

Sealed bids will be received on **Tuesday, December 3, 2024**, by the Terrebonne Parish Consolidated Government (TPCG) Purchasing Division, at the City of Houma Service Complex, 301 Plant Road, in Houma, Louisiana until **2:00 P.M.** as shown on the Purchasing Division Conference Room Clock, and, at the time and place, shall be publicly opened and read aloud. **No bids will be received after 2:00 P.M.**

### 4. Proper Preparation and Submission of Bids


- a. Bids to be submitted by the time and at place indicated in the Invitation to Bidders and shall be enclosed in a sealed envelope.
- b. Envelope shall include Project title and name, address and state license number of the Bidder.
- c. Each Bid Proposal packet shall include:
  - i. Completed Uniform Public Work Bid Form
  - ii. Signature Authorization with written evidence of authority (LA R.S. 38:2212(B)(5))
  - iii. Bid Bond with Power of Attorney, or Certified Check or Cashier's Check,
  - iv. Completed Unit Price Form.

### 5. Bid Completeness Requirements – including, but not limited to, the following:

- a. Acknowledgement of Addenda on Bid Proposal Form.
- b. Properly fill in unit price and extension price of each item included in the Bid Form.
- c. Complete bidder information as requested.
- d. Sign and Attest the bid.

### 6. Project Addenda:

- a. Clarifications in response to questions concerning Contract Documents will be issued in an Addendum.



- b. Send all questions to parties stated in the bid documents. Any questions submitted outside of this provided email address will not be considered. – **Please be sure to add the project name to the subject line.**
- c. Addenda will be available at <http://www.centralbidding.com> by clicking on the Project Link.

#### **7. Contract Documents and Requirements:**

- a. Contract Documents include complete Plan, Specifications, Addenda and Reference Documents.

#### **8. General Project Information:**

- a. Contract Time: 540 Calendar Days from Notice to Proceed.(including 240 day assembly period)
- b. Estimated Project Budget: \$ 6,990,685.00
- c. Required Contractor's License: Highway, Street, and Bridge Construction
- d. Liquidated Damages: **\$5,000.00 per day.**
- e. There will be mandatory weekly or bi-weekly progress meetings with Engineer and Owner personnel during construction.

#### **9. Special Provisions Highlights**

Discussion

#### **10. Agency/Owner Comments**

#### **11. Bid Questions & Responses**

- a. Questions received prior to this pre-bid conference will be addressed in an upcoming addendum within the following days. FYI: Addendum 1 & 2 have been posted.
- b. All future questions shall be in writing and sent to the email address [stated in advertisement](#) We will not accept any questions over the phone or sent to direct emails.
- c. The last day to submit written questions will be **Friday, November 22, 2024 until 2:00 P.M.**

