

TERREBONNE PARISH CONSOLIDATED GOVERNMENT

SOUTH PLANT OXIDATION POND CELL NO. 2 LEVEE REPAIRS

(HURRICANE IDA)

PARISH PROJECT NO. FRA-006

FEMA NO. 815690

ADDENDUM NO. 2

Date Issued: July 30, 2026

This Addendum No. 2 shall be part of the above referenced project.

Acknowledge receipt of this Addendum No. 2 by inserting its number in the space provided in the Louisiana Uniform Public Work Bid Form of the Request for Proposals. Failure to do so may subject the bidder to disqualification.



Kevan Keiser, P.E.

GIS Engineering, LLC.

TERREBONNE PARISH CONSOLIDATED GOVERNMENT
SOUTH PLANT OXIDATION POND CELL NO. 2 LEVEE REPAIRS
(HURRICANE IDA)
PARISH PROJECT NO. FRA-006
FEMA NO. 815690

This Addendum is issued for the purpose of modifying, clarifying, or revising, as applicable, the specified items of the original Contract Documents. It is also issued for the purpose of adding, as applicable, the attached specified items to the original Contract Documents, or deleting, as applicable, the attached specified items from the original Contract Documents. The Addendum and attachments shall be construed as much a part of the original Contract Documents as contained therein. Changes made by Addenda shall take precedence over original Contract Documents.

PART I – WRITTEN CONTRACTORS QUESTIONS

PART II – MODIFICATIONS TO CONTRACT DOCUMENTS, TECHNICAL SPECIFICATIONS, PLANS, AND OTHER DOCUMENTS

PART III – REQUESTS FOR APPROVED EQUAL

PART IV – ATTACHMENTS

1. Section C – Uniform Public Works Bid Form (Revised as per Addendum No. 2)

PART I – Written Contractors’ Questions

NOTE – The responses presented in PART I may differ from those presented in the Pre-Bid Conference. The responses in PART I are current as of the date of this Addendum and if different supersede those provided at the Pre-Bid Conference or any previous addenda.

Contractors’ General Questions Received

- 1. Please clarify how the imported earthen embankment will be paid. The specifications refer to both survey pit cross sections w/licensed surveyor and or truck measure delivered to the site. The truck measure option is what was done in the past on a similar project in recent past (tpcg -north plant sewer pond).**

Response: Please refer to Section 02330 Embankment. Either method is acceptable. If the trucking method is utilized, it must accompany a haul ticket.

- 2. Please clarify what are the removal of obstructions task of work associated with this pay item.**

Response: Please refer to Technical Specification Section 02231, Paragraphs 3.2.1, 3.3.1, 3.3.5, 3.4.1 for further clarifications.

- 3. Please clarify what is required of the existing concrete matts where the new fabric and matts are to be placed.**

Response: The existing concrete mats can be pushed into Cell No. 2. The new fabric and concrete mats shall be installed to the lines and grades as shown on the plans and according to the manufacturer’s guidelines.

- 4. Is the fabric pay quantity on this project for both under new rip rap and new concrete matts for this project?**

Response: The Geofabric shall be placed under new concrete mats only. The estimated bid quantity has been revised to 4,100 SY for Geofabric.

- 5. Will the fabric for under new rip rap be placed directly over existing rip rap where required on plans?**

Response: No geotextile fabric will be under the rip rap.

- 6. Will fabric be required under 610 limestone placement? (Segment 2 and 3)**

Response: No.

- 7. Will loaded tandem or triaxle trucks be allowed to drive access road between cell 1 and 3 for material deliveries to stage materials at corner of cell 1,2,3?**

Response: Yes; however, please refer to Technical Specification 02713-No. 610 Limestone, 1.5 Basis of Payment.

- 8. Are we to put the clearing and grubbing the in Removal of Structures and Obstructions Unit Price or in the Levee Embankment Unit Price. If we are to put it in the levee embankment, how are you wanting us to go about bidding the unit price since quantities will be different. The specs make it seem as though its missing a unit price as it specifically calls out the “Clearing and Grubbing” Unit Price.**

Response: Clearing and Grubbing will be a separate pay item and will be reflected in the revised Section C – Bid Form.

- 9. Are you able to give us a CY quantity of proposed clearing and grubbing to bid off of?**

Response: No

- 10. Also, a little confused on the section views shown on the plans, specifically segment 1. It shows on sheet 6 to remove about 0.5’ all throughout the profile view. It also confirms this on sheet 05 in the typical section. However, on almost all section views on sheet 11, all but 1 show no clearing and grubbing to be performed.**

Response: Contractor is to Clear and Grub as shown on the profile. Please reference Note under Cross Section on Sheet 11 for clarification on other sections.

- 11. Will we need to remove all organic materials from existing before placing the new embankment, concrete mats, limestone, etc? If so, according to the Segment 2 typical section, is looks as though there will need to be embankment and concrete matting that will go below the waterline. Will we need to figure for removing and replacing any materials under the waterline or can we just place the fill as required?**

Response: For installation of material under the waterline, place fill material and concrete mats as depicted on the plans to the lines and grades.

PART II – Modifications To Contract Documents, Technical Specifications, Plans, and Other Documents

Contract Documents:

1. Section C – Uniform Public Works Bid Form
 - a. Please remove and replace with the revised Uniform Public Works Bid Form provided in Part IV of this Addendum.

Technical Specifications:

NONE

Plans

NONE

PART III – Request for Approved Equal

1. Armorform Articulating Block Mat

Response: The product submitted would need further information to be approved as an equal.

1. Submit engineered hydraulic calculations verifying:
 - 18 lb/ft² shear resistance
 - 30 ft/sec velocity resistance.
2. Demonstrate compliance with the specified 4,000 psi compressive strength.

PART IV - ATTACHMENTS

Revised Section C – Uniform Public Works Bid Form

SECTION C
LOUISIANA UNIFORM PUBLIC WORK BID FORM

TO: Terrebonne Parish Consolidated Government
City of Houma Service Complex
301 Plant Road
Houma, LA 70363
(Owner to provide name and address of owner)

BID FOR: South Plant Oxidation Pond
Cell No. 2 Levee Repairs
(Hurricane Francine)
TPCG No. FRA-0006 FEMA No. 815690
(Owner to provide name of project and other identifying information)

The undersigned bidder hereby declares and represents that she/he; a) has carefully examined and understands the Bidding Documents, b) has not received, relied on, or based his bid on any verbal instructions contrary to the Bidding Documents or any addenda, c) has personally inspected and is familiar with the project site, and hereby proposes to provide all labor, materials, tools, appliances and facilities as required to perform, in a workmanlike manner, all work and services for the construction and completion of the referenced project, all in strict accordance with the Bidding Documents prepared by: **GIS Engineering, LLC** and dated: **June 2026**

(Owner to provide name of entity preparing bidding documents.)

Bidders must acknowledge all addenda. The Bidder acknowledges receipt of the following **ADDENDA:** (Enter the number the Designer has assigned to each of the addenda that the Bidder is acknowledging) _____

TOTAL BASE BID: For all work required by the Bidding Documents (including any and all unit prices designated "Base Bid" * but not alternates) the sum of:

_____ Dollars (\$ _____)

ALTERNATES: For any and all work required by the Bidding Documents for Alternates including any and all unit prices designated as alternates in the unit price description.

Alternate No. 1 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:

_____ N/A _____ Dollars (\$ _____ N/A _____)

Alternate No. 2 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:

_____ N/A _____ Dollars (\$ _____ N/A _____)

Alternate No. 3 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:

_____ N/A _____ Dollars (\$ _____ N/A _____)

NAME OF BIDDER: _____

ADDRESS OF BIDDER: _____

LOUISIANA CONTRACTOR'S LICENSE NUMBER: _____

NAME OF AUTHORIZED SIGNATORY OF BIDDER: _____

TITLE OF AUTHORIZED SIGNATORY OF BIDDER: _____

SIGNATURE OF AUTHORIZED SIGNATORY OF BIDDER **: _____

DATE: _____

THE FOLLOWING ITEMS ARE TO BE INCLUDED WITH THE SUBMISSION OF THIS LOUISIANA UNIFORM PUBLIC WORK BID FORM:

* The Unit Price Form shall be used if the contract includes unit prices. Otherwise it is not required and need not be included with the form. The number of unit prices that may be included is not limited and additional sheets may be included if needed.

** **A CORPORATE RESOLUTION OR WRITTEN EVIDENCE** of the authority of the person signing the bid for the public work as prescribed by LA R.S. 38:2212(B)(5).

BID SECURITY in the form of a bid bond, certified check or cashier's check as prescribed by LA RS 38:2218(A) attached to and made a part of this bid.

SECTION C
LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

TO: Terrebonne Parish Consolidated Government
City of Houma Service Complex
301 Plant Road
Houma, LA 70363
(Owner to provide name and address of owner)

BID FOR: South Plant Oxidation Pond
Cell No. 2 Levee Repairs
Hurricane Francine)
TPCG No. FRA-0006 FEMA No. 815690
(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Mobilization & Demobilization		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
01	1	Lump Sum		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Construction Layout		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
02	1	Lump Sum		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Removal of Structures and Obstructions		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
03	1	Lump Sum		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Levee Embankment (Hauling, Placing, & Compacting)		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
04	1,533	Cubic Yards		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Seeding		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
05	2	Acres		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Rip Rap		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
06	11,455	Tons		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Geotextile Fabric (Class D)		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
07	4,100	Square Yard		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Articulated Concrete Mats		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
08	36,800	Square Foot		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____	Access Road Maintenance Aggregate (610 Limestone)		
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
09	1,000	Tons		

DESCRIPTION:	☒ Base Bid or ☐ Alt.# ____		Clearing and Grubbing	
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION <i>(Quantity times Unit Price)</i>
10	1	Lump Sum		

Wording for “DESCRIPTION” is to be provided by the Owner.

All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner